

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1 OF 4 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0002		3. EFFECTIVE DATE 03/26/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 08-0152
6. ISSUED BY CODE		CODE mks	7. ADMINISTERED BY (If other than Item 6) CODE	
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521		See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-08-R-0152
			x	9B. DATED (SEE ITEM 11) 03/24/09
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

08-0152, Renovate BOQ 2611

1. Question: For toilet accessories on Sheet A-3, it says "accessories shall be polished chrome," but next to the toilet paper dispenser it says "with a matching finish brass roller." Are the accessories supposed to be chrome or brass?

1. Answer: All new fixtures will have a polished chrome finish and not brass.

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

2. Question: Are new accessories needed in the women's and men's gang bathroom on the first floor?

2. Answer: No new fixtures are required in gang bathroom on first floor.

3. Question: The dimensions given for the push plates and kick plates are not valid dimensions. Please list out how many kick plates and new push plates are needed with valid dimensions.

3. Answer: The dimensions as stated in note #28 should read:
(Eight) 8" x 2'-10" and (one) 6" x 2'-10."

4. Question: Are the existing lock sets cylindrical?

4. Answer: Yes, the existing locksets are cylindrical.

5. Question: Are the entrances to living units the only doors that had deadbolts?

5. Answer: The entrance to the living units are the only doors that had deadbolts.

6. Question: Are all doors supposed to receive new locksets, or just the exterior entrance locations and interior hallway locations?

6. Answer: The only doors to receive new locksets are the exterior entrances and the interior corridor locations including storage rooms. New locksets will have Round knobs.

7. Question: On sheet A-1: Note 15 is not shown in the construction notes for this page.

7. Answer: Sheet A-1, #15 on Demo Legend should read: "Remove existing toilet partitions."

8. Question: On sheet A-3, Note 14: Double drop-in sink in common kitchen area is not shown on plumbing drawings.
8. Answer: The Contractor should refer to reference drawing P-1, NAVFAC Drawing No. 4152822 for plumbing information for new sink to replace existing in Common Kitchen Area. No additional plumbing should be required.
9. Question: Could a hook-up diagram for plumbing and exhaust be provided for kitchenette units?
9. Answer: Supplier can also be installer. Have confirmed with Supplier that hook-diagrams would not be needed if Supplier installed.
10. Question: On sheet P-1, Note 1, we are directed to remove and reinstall all domestic water piping and all waste and vent piping. All system piping configurations must be estimated from poor reference drawings from 1963. Is this the intent of the contract?
10. Answer: Sheet P-1 Demolition note: Note #4 makes an exception to note 1. Fixtures in common area toilets on First floor are to remain. The reference drawing is what is available for demolition. If you don't remove a urinal, disregard spec reference to urinal on sheet P-1.
11. Question: On sheet P-1, Note 4, we are directed to remove all the fixtures in the living areas and not in the common areas. No urinals are in the living areas but there is a urinal specification in the "Toilet Fixture Spec". There is also a large bathroom on the first floor and water coolers in the hallways that will not be replaced. Is this your intent?
11. Answer: Install two new Electric Water Coolers at the same location of the existing ones.
12. Question: Sheet A-3, note 13 – Provide toilet accessories. Locations and quantities unknown.
12. Answer: Toilet accessories are as noted on Sheet A-3, note #12 and note #13. The location and quantities are clearly stated. These are to be provided in each renovated toilet.

13. Question: Sheet A-3, note 24 – Provide urinal partition in men’s toilet, size to match existing. Size unknown.

13. Answer: Provide urinal partition in size 18” x 24”.

14. Answer: Sheet A-3, note 28 – new push plates/ kick plates where they are existing, match finish. Locations, finish and quantities unknown.

14. Answer: The quantities for the Push and Kick Plates are as stated in note #28. The finish will be Bright Brass to match existing. All are located on interior corridors and are readily accessible so locations should not affect bid prices.

15. Question: Sheet A-3, note 29 – install new hardware where locksets are existing. Locations and quantities unknown. Are the locksets and fillers the only items being furnished?

15. Answer: Finish hardware will be Stanley/Best and the following model numbers and quantities:

(1)	45H7-4-S-605-RHRB	Mortise Entrance Function
(1)	63K0-L-4-D-S3-605	Cylindrical Privacy Function
(1)	63K0-N-4-D-S3-605	Cylindrical Passage Function
(8)	83K0-N-4-D-S3-605	Cylindrical Passage Function
(22)	83K7-AB-4-D-S3-605	Cylindrical Entrance Function
(6)	83K7-D-4-D-63-605	Cylindrical Storeroom Function
(17)	DJ-FPK-161-PC	Filler Plate kit for Crossbore and door Edge

Finish is to match knobs.