

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT	1. CONTRACT ID CODE	PAGE OF PAGES 1 2
---	---------------------	----------------------

2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0009	3. EFFECTIVE DATE 03/30/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 08-0152
---	-------------------------------	----------------------------------	---

6. ISSUED BY CODE Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6
--	---

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-08-R-0152
	X	9B. DATED (SEE ITEM 11) 03/24/09
		10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
(a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

08-0152, Renovate BOQ 2611

1. Question: Are the furniture and window treatments the responsibility of the contractor? If so, are we to store and put back or is the gov't taking responsibility?

1. Answer: There is no window treatment in BOQ 2611. Existing window blinds will be removed, as new mini-blinds are a part of this Contract. The furniture will be removed and stored by the Contractor during construction and the Contractor, not the Government, will be responsible for its condition during removal, storage, and reinstallation. The Government will inspect at removal and at reinstallation.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	16C. DATE SIGNED

CONTINUATION SHEET

2. Question: Sheet A-2 shower base detail shows the existing ceramic floor tile to be removed, however, shows the existing mortar base (mud bed) but does not indicate to remove, implying that it is to remain. During the demolition of the floor tile the mud bed will be damaged and will need to be removed and replaced. Please advise.
2. Answer: The existing ceramic tile is to be removed. There is no implication that the existing mortar base is to remain. The existing mortar base is to be removed so a new mortar base can be installed with the new tile.