

**NAVFAC  
SPECIFICATION**

**4656875, Install Traffic  
Signals and Islands Near  
B-3451**

**AMENDMENT NO. 0001**

## **IMPORTANT**

**This amendment should be acknowledged when your bid is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of the bid.**

**If your bid has been submitted prior to the receipt of this amendment, acknowledgement should be made by telegram, which should state whether the price contained in your sealed bid is to remain unchanged, is to be decreased by an amount, or is to be increased by an amount. The acknowledgement must be received prior to bid opening time.**

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>		1. CONTRACT ID CODE	PAGE	OF PAGES
			1	1

2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 3/27/2009	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
---------------------------------------	--------------------------------	----------------------------------	--------------------------------

6. ISSUED BY <b>CG MCAS Cherry Point FACILITIES, ROICC B-163, CURTIS ROAD PSC BOX 8006 CHERRY POINT, NC 28533</b>	Code N40085	7. ADMINISTERED BY (If other than item 6.)	Code
--	-------------	--	------

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)  <b>AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR BID</b>	<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION 4656875
		9B. DATED (SEE ITEM 11) 3/23/2009
	<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE	

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers  is extended  is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

**12. ACCOUNTING AND APPROPRIATION DATA (if required)**

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

- A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
- B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
- C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
- D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor  is not  is required to sign this document and return **original** to the issuing office.

**14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)**

4656875, INSTALL TRAFFIC SIGNS AND ISLANDS NEAR B-3451, MARINE CORPS AIR STATION, CHERRY POINT, NORTH CAROLINA

This amendment is issued to answer questions submitted in Requests For Information:

1. Q. On all sites, what is the radius for arcs along the edge of pavement, back of curb, and planters?
  - A. Match existing for curbs. Islands – minimum radii are given.
2. Q. Need the width on “all” parking spaces.
  - A. 9 feet.
3. Q. At mess hall, what is the minimum distance between the traffic islands from B/C to B/C?
  - A. Reference is face of curb and existing parking stall lines opposite side of island from driveway. Government can point them out during layout to awarded contractor.
4. Q. Does the opening between the proposed traffic island need to line up with the street?
  - A. They relate to the mess hall driveway (see centerline shown.) But ultimately they reference the existing stall markings noted in question 3 above.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY	16C. DATE SIGNED
_____ (Signature of person authorized to sign)		_____ (Signature of Contracting Officer)	