

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE	PAGE 1 OF 3 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0002		3. EFFECTIVE DATE 03/23/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 09-0425	
6. ISSUED BY CODE		raa	7. ADMINISTERED BY (If other than Item 6) CODE		See Item 6
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521					
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-09-R-0425
				x	9B. DATED (SEE ITEM 11) 03/12/09
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE				

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.  
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
 (a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;  
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

09-0425 Building H1 3ES Wing Renovations

SEE CONTINUATION SHEET

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

**CONTINUATION SHEET**

1. **Question:** Is the new frame at room 3E 30 supposed to be a hollow metal frame with wood casing?

**Answer:** The frame shall be a metal frame as specified on Item 3, under Special Structural Instructions on page 11. New stainable trim shall be installed around the door frame on both sides of the opening to match the other doors in the surrounding area as stated in item 3e on page 3.

2. **Question:** Can we reuse the existing hardware at the door leading from room 3E 46 to room 3E52 at the new opening?

**Answer:** No, new hardware shall be used on the new door in room 3E30.

3. **Question:** Does the new opening need a new hollow metal frame with wood casing?

**Answer:** Room 3E 46 does not have a new opening, so the answer is no.

4. **Question:** Are the mirrors at all the head supposed to be a wood framed mirror or stainless steel channel framed mirror? Head #1 says wood framed mirror, but the other mirrors do not say.

**Answer:** The mirrors in all of the heads, with the exception of head #4 & head #5, shall be a wood framed mirror per specifications listed in item 12 on page 14. The mirrors in head #4 & #5 shall remain existing.

5. **Question:** At head #6, #7 and #9 it says to remove and dispose of mirrors. Do you want me to quote a new mirror?

**Answer:** Yes, the mirrors in all of the heads, with the exception of head #4 & head #5, shall be a wood framed mirror per specifications listed in item 12 on page 14. The mirrors in head #4 & #5 shall remain existing.

6. **Question:** Are any openings rated?

**Answer:** Yes, all openings shall have a Class 3, 3/4 hour fire rating.

N40085-09-R-0425  
Amendment 0002  
Page 3 of 3

**Additional Information:**

Item 2 under "Room 3E 46 Install" page 5 should read as follows:

2. Remove door leading from room 3E 46 into room 3E52. Save this door and reuse it for the new door in the door opening between room 3E47 into 3E48.