

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT	1. CONTRACT ID CODE	PAGE OF PAGES 1 4
---	---------------------	----------------------

2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0004	3. EFFECTIVE DATE 03/24/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 09-0425
---	-------------------------------	----------------------------------	---

6. ISSUED BY CODE raa Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6
---	---

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-09-R-0425
	x	9B. DATED (SEE ITEM 11) 03/12/09
		10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
(a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

09-0425 Building H1 3ES Wing Renovations

Add the attached PDF "Amend 0004 Dwg 090425" to the Maps & Floor Plans provided with the RFP package. These two drawings detail changes made by this amendment.

See the continuation sheet for additional information and changes.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	16C. DATE SIGNED

CONTINUATION SHEET

1. **Question:** Do the communication lines on the wall in Room 3E30 get relocated for new wall installation?

Answer: Yes, relocate the communication lines on the wall between room 3E30 and 3E32 to allow installation of the new door opening and the new door. See Floor Plan #6 for location of the wall. Contractor shall not relocate any cipher net communication lines. Contractor shall provide a 5 day notice to the POC in order for the POC to make arrangements for the cipher net communication lines to be relocated by authorized personnel.

2. **Question:** Do you want carpet pad with the carpet?

Answer: Yes, all new carpet shall be installed with 3/8" carpet padding. This carpet padding shall be installed using a double stick method per the carpet and padding manufacturer's specification. This double stick method shall consist of the padding being glued to both the carpet and the floor. The padding can be pre-glued at the carpet manufacturer's site or glued at the work site. The contractor shall ensure that all doors close properly after the carpet and carpet padding are installed. Contractor shall make any necessary adjustments to the doors to allow proper closure of the doors.

3. **Question:** Do you want the carpet in the hallways replaced?

Answer: Yes, all of the carpet in the corridor shall be included in the removal of the carpet, asbestos floor tile and asbestos mastic. This corridor shall also be added to the installation of new carpet padding and new green carpet with the same specifications and criteria as the rest of the carpet replacement in the 3ES Wing. See attached Floor Plan # 4 (REV) for area locations.

4. **Question:** Floor Plan # 4 shows carpet on the floors in the head. Do you want carpet on the floors in the heads?

Answer: No, they get ceramic floor tile. Floor Plan # 4 (REV) has been changed to show that none of the floors in the heads receive carpet.

5. **Question:** Do all submittals have to be submitted at the same time.

Answer: Yes, all submittals shall be submitted at the same time so occupant will be able to visualize the finished product.

6. **Question:** Do the walls in the heads get base cove molding?

Answer: No, install ceramic base cove molding in all of the heads (9ea).

7. **Question:** Does the existing conduit on the walls get painted?

Answer: All previously painted areas shall be painted, including conduit.

8. **Question:** Who is responsible for the removing and resetting of the modular desk in Room 3E75 (Briefing Conference Room)?

Answer: The POC is responsible for removing, storing, and resetting the modular desk in Room 3E75 (Briefing Conference Room). The contractor shall contact the POC one week in advance prior to starting work in the Room 3E75 (Briefing Conference Room) to allow POC to make arrangements to have this modular desk removed. The contractor shall notify the POC when this modular desk can be reset.

ADDITIONAL CHANGES:

Change #1: Change item 4 on page 2 under “Walls” to read “ Remove and replace any existing rubber base cove molding **in the office spaces** and replace with new rubber base cove molding.

Change #2: Delete the sentence” **Do not remove any other carpet from the corridor areas identified as 3E45 & 3E 68**” from item #1 on page 2 under the “Floor Covering” section. The purpose of this change is to have all carpet replaced.

Change #3: Delete item # 5 on page 2 which reads” The carpet in the main corridor areas, identified as 3E45 & 3E 68, shall not be removed, but shall be professionally cleaned under this contract”.

Change #4: The words “or cleaned floor” shall be deleted from the sentence in item 6 on page 2 under the “Floor Covering” section.

Change #5: Change the” approximately 9,500 square feet” in the sentence in item 2, under **CARPET REPLACEMENT** on page 7 to read “approximately 16,000 square feet”.

Change #6: Delete the entire section on page 7 that reads “*CARPET CLEANING (See attached Floor Plan # 1 & Floor Plan # 4 for location). Professionally clean the carpet in corridor 3E45, 3E45B and 3E68.*” Carpet cleaning is not necessary since all carpet is going to be replaced.

Change #7: Change the” approximately 9,500 square feet of new direct glue down” in the sentence in item 2 on page 12, under the” **CARPET AND BASE COVE MOLDING**” section to read “approximately 16,000 square feet of new double stick glue down.”

ADD THE FOLLOWING TO THE” SUBMITTALS” SECTION:

Addition # 1:

Carpet Padding: The carpet padding shall be installed under all new carpet. Padding shall be equal to Shaw™ Carpet Corporation, Philadelphia style.

- a. 3/8” Synthetic Fiber Pad.
- b. 32oz, 8.9lb.
- c. 10 year quality assurance warranty.

Addition # 2:

Variations in the carpet color is **NOT** acceptable.