

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE 1 OF 4 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0005		3. EFFECTIVE DATE 04/02/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 09-0133
6. ISSUED BY CODE		CODE	7. ADMINISTERED BY (If other than Item 6) CODE	
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521		See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-09-R-0133
			X	9B. DATED (SEE ITEM 11) 03/17/09
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.  
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
 (a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;  
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

09-0133, Major Interior/Exterior Repairs, Building 323

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Question: What is meant by "panel type underlayment" mentioned in the Resilient Flooring Specs in Section 2.3 - Surface Preparation Materials?

1. Answer: There is no panel type under layment to be used on this project.

**2. Question: In the Room Finish Schedule, they refer to Vinyl Tile. Do they mean VCT?**

**2. Answer: Vinyl tile in the finish schedule is VCT.**

3. Question: In the Resilient Flooring Specs, 1.1 References, it mentions Sheet Vinyl Floor Covering with Backing, Sheet Vinyl Floor Covering w/out Backing, Rubber Floor Tile, Rubber Sheet Floor Covering, Sheet Linoleum Floor Covering, Linoleum Floor Tile and Cork Floor Tiles. Nowhere in the Finish Schedule are these listed. Are these items to be used anywhere?

3. Answer: All resilient tile on the 323 project is VCT. The other types of flooring in the spec are not used on this project.

**4. Question: Please confirm areas where VCT exists and needs to be removed. Some areas shown with existing VCT were not detected in the walk-through.**

**4. Answer: All VCT in the building is to be removed. The corridors, toilets, and some offices do not have VCT.**

5. Question: Amendment #1 drawings contain a sheet M-1 that is from Kyle bush Morrisville, NC project? There is an M-1 in the original drawings. Please clarify whether the original M-1 is to be used or if there is a revised M-1 and if so please provide.

5. Answer: Sheet M-1 of the original building is correct.

**6. Question: There are 34 VAV boxes shown on the M-sheets. They require 120vac power for the controls in each box. No power is shown on the E-sheets. Please provide a power sources on the E-sheets for these boxes.**

**6. Answer: Provide four 20 amp branch circuits to provide power to the VAV boxes.**

7. Question: Re: Spec Section 09900 1.3.1 SSPC QP 1 Certification  
Does the requirement to be certified by the society of protective coatings apply to this project?  
Will certification be required?

7. Answer: Provide certification as required by the specification.

**8. Question: The ductwork on sheet M-3 from AHU-4 that feeds rooms 230, 231, 232 has VAV drawn in, but they are not given a number. Could we get information on these?**

**8. Answer: The VAV Boxes are VAV-35 for room 230, VAV-36 for room 231 and VAV-37 for room 232. VAV-35 is 540 CFM MAX/ 135 CFM MIN and 10". VAV-36 and VAV-37 is 480 CFM MAX/ 120 CFM MIN and 10".**

9. Question: Sheet E-7 of the drawings shows a new 225kVA transformer and specification section 26 12 19.10, 2.2.2 note be reads "Transformer shall be rated 300kVA". Which is correct?

9. Answer: The transformer is 225 KVA.

**10. Question: Please provide clarification on the electrical as follows: Drawings call for a Main Distribution Panel (MDP) on the electrical drawings, but do not show a panel design or legend. They also do not show the size for conduits & cables service to this panel on the electrical riser.**

**10. Answer: Change panels A thru F to 150 amp main breaker panels. Panel MDP is a 600 amp main breaker with six 150 amp 3 pole breakers feed with 3 set of 4#4/0 in 3" conduit.**

11. Question: # 2 Panel F, is shown to be a 400 amp, is this correct?

11. Answer: Refer to Answer for #10 above.

**12. Question: There is no mention about backbone cabling for Telephone or Fiber.**

**12. Answer: There is no requirement for backbone fiber or copper.**

13. Provide two 3" conduits between the two telephone rooms. Each conduit shall have pull boxes every 50' and at ever 90 degree of change of direction. All changes in direction shall be accomplished via 36" radius bends.

**14. PVC DWV piping is acceptable throughout the building.**

15. All exterior wall use detail 2/A 13. Delete detail 6/A13.