

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>	1. CONTRACT ID CODE	PAGE OF PAGES 1 2
---	---------------------	----------------------

2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0008	3. EFFECTIVE DATE 04/08/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 09-0133
---	-------------------------------	----------------------------------	---

6. ISSUED BY CODE  Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521	7. ADMINISTERED BY (If other than Item 6) CODE  See Item 6
--	---

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-09-R-0133
	X	9B. DATED (SEE ITEM 11) 03/17/09
		10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.  
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
(a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

09-0133, Major Interior/Exterior Repairs, Building 323

1. Delete Item 19 on Amendment 0001.

2. In addition to work indicated on the drawings, provide 200 2x2x4 metallic outlet boxes with 3/4" conduit from box to a point above ceiling with 90 degree bend and blank cover plates in locations designated by the contracting officer. These items have nothing to do with the electrical system or telephone system for the building.

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)
15B. CONTRACTOR/OFFEROR  (Signature of person authorized to sign)	15C. DATE SIGNED
16B. UNITED STATES OF AMERICA  (Signature of Contracting Officer)	16C. DATE SIGNED

CONTINUATION SHEET

3. In addition to work indicated on the drawings, Provide 200 2x4x4 metallic outlet boxes with metallic 4x4 to 2 x 4 reducer rings, 1" conduit from box to a point above ceiling with 90 degree bend, and blank cover plates in locations designated by the contracting officer. These items have nothing to do with the electrical system or telephone system for the building.
4. E3 Change two fixture type c in addition to fixture type F.
5. E2 and E3 Note that symbol for fire alarm pull station is similar to symbol for fixture type f. Fixture type f is only shown in the addition. All other occurrences of the symbol are fire alarm pull stations.
6. Section 09 65 00 - Resilient Flooring, Part 2 Products, 2.1 Vinyl Composition Tile - Provide ASTM F 1066, Class 1, Vinyl Composition Tile, Solid Color.
7. Provide addressable fire alarm system with autodialer. Provide 1" conduit from fire alarm panel to telephone room with 4 cat5e. Provide all devices shown on the drawings and those required by NFPA 72, and UFC 3-600-01 Fire Protection Engineering for Facilities.
8. Provide Marine Corps mass notification system per UFC 4-021-01 Design and O&M: Mass Notification Systems. Note that the UFC requires a separate Mass Notification system. The only interconnection between the fire alarm and the mass notification system is a jumper that silences the fire alarm system during mass notifications. The mass notification system shall be per the UFC except: LED Displays are not required. Locate Mass Notification Strobes at same locations as Fire Alarm Strobes.
9. Question: Under the specifications on building 323, Section 23 73 33, Page 11, 2.2.1 require that motors, controllers, contactors and disconnects be furnished with respective pieces of equipment. Under section 26 00 00 Page 6, Section 1.9.3, New Work, the disconnects are referred to as integral disconnects. Section 26 00 00 seems to agree with the electrical drawings showing the EC furnishing external disconnects. Also the chiller disconnect is part of the service and is listed as service entrance disconnect.

Is the Electrical contractor responsible for the disconnects that are not integral to the equipment?

9. Answer: The general/prime contractors need to answer this question