

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0004		3. EFFECTIVE DATE 08/11/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 09-5372	
6. ISSUED BY CODE sgj  Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521		7. ADMINISTERED BY (If other than Item 6) CODE  See Item 6			
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-09-R-5372
				X	9B. DATED (SEE ITEM 11) 07/30/09
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE			

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
 (a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

N40085-09-R-5372, P1156B, Relocate Skeet Range

~SEE CONTINUATION SHEET~

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Question: Drawing A-601B, Section Through Opening indicates a wood platform to be built on Level 2 and cast in place concrete platform on Level 1. However, Drawing A-101B indicates that both a wood and a concrete platform are to be built on Level 1 along the south wall. Which is correct? Please verify and provide direction.

Answer: On Drawing A-101B, First Floor Plan, New Work Note 7 is incorrect and should be deleted. Note 5 is correct. The details on A-601B are correct as shown. The lower platform is concrete and the upper platform is wood.

2. Question: Drawing A-601B, Detail B3 indicates fill on both sides of the CMU Wall. However, Drawings C-111 and C501, Detail A2 indicates a concrete sidewalk on the inside of the wall and fill on the outside. Which is correct? Please verify.

Answer: Drawing A-601B is the detail for construction of the wall and is correct for that work. Sidewalks are required between the walls as shown on civil drawings C-111 AND C501. See structural drawings for wall footer details.

3. Question: Drawing C-502 indicates references numbers shown on the trap stations. Will the contractor have to provide any pavement markings at the trap stations?

Answer: Numbers indicated in details on C-502 are for reference only, paint marking is not required.

4. Question: Spec Section 32 11 24, Paragraph 3.8 indicates that after construction is completed maintain the base course throughout, except where portion of the succeeding course is under construction thereon. Will the contractor be responsible for maintaining the base course after the project has been completed? If so, for how long?

Answer: Contractor is responsible for maintaining aggregate roadway until acceptance of project by the Government.