

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0005		3. EFFECTIVE DATE 08/12/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 09-5372	
6. ISSUED BY CODE		sgj	7. ADMINISTERED BY (If other than Item 6) CODE		See Item 6
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521					
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-09-R-5372
				x	9B. DATED (SEE ITEM 11) 07/30/09
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

N40085-09-R-5372, P1156B, Relocate Skeet Range

The date for the receipt of proposals is hereby changed to 1100, Friday, 14 August 2009.

~SEE CONTINUATION SHEET~

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Question: I can not find a padlock made out of stainless steel, only brass. Please verify a padlock made out of brass is okay.

Answer: The following is hereby incorporated into the RFP dated 30 July 2009:

Specification Section 08 71 00 Door Hardware, Paragraph 2.2.17 Padlocks, ASTM F 883, minimum grade 3, options B and E

2. Question: Drawing S-001, Note 7 indicates that where no reinforcing is indicated in slabs on grade, provide 6x6 / 2.9x2.9 WWR. However, Drawing C-501, Detail A3 does not indicate any reinforcement for the exterior walks. Will WWR be required for the exterior walks? Please verify.

Answer: Notes on Drawing S-001 apply to building slabs, detail A3 on C-501 applies to exterior walks including walk between walls outside of Skeet Houses.

3. Question: Spec Section 32 11 24, Paragraph 3.5 indicates that ABC Stone will be compacted to 100% density. However, Drawing C-501, Detail D3 indicates the ABC Stone will be compacted to 95% density. Which is correct?

Answer: Delete reference to compaction requirements for subgrade and base course material noted in detail D3 on C-501. Specifications shall govern.

4. Question: Which proctor is required for the ABC Stone Standard or Modified?

Answer: Modified Proctor as indicated in specifications.

5. Question: On Sheet E-6 it indicates a universal duct bank detail. Is the 2" conduit for the circuits feeding the skeet houses, trap houses and all other circuits excluding the primary circuit and feeder to panel P1 direct buried or duct bank?

Answer: Direct buried in 2" conduit.